

Drw. nr.	Contents of drawing	Date	Rev.	Rev. date
S150DM01	Primo Skyline 150 / Basic panel	25.10.2019	d	04.10.2023
S150DM02	Primo Skyline 150 / Joints overview	13.11.2019	e	04.10.2023
S150DM03	Primo Skyline 150 / Corner panel	25.10.2019	d	04.10.2023



City sector	Block	Site/Reg. nr.	File nr.		
Building type			Drawing type		Nr.
Building, Name and address			Contents of drawing		Scale
			Primo Skyline 150		1:10
			Dimensional drawings		
Date	25.10.2019	Designer	Ruukki		Rev.
Drawn by	Checked				



Contents of drawing

Primo Skyline 150

Basic panel

Dimensional drawing

Date 25.10.2019

Rev. date 04.10.2023

Drawn by Ruukki

Rev. P03

Work nr.

Drw. nr.

Rev.

S150DM01




d

Scale 1:10

Building

File nr.

Bracket cutouts/side	
Height	Cutouts
< 950	1
950-1699	2
1700-2449	3
2450-3199	4
3200-3950	5
> 3950	6




panel depth C = 40 mm
horizontal joint Dh = 5-35 mm
vertical joint Dv = 5-30 mm
material thickness t = 4.0 mm (ACM)
weep holes at the bottom 15x5 mm, max c/c 300mm

Amin, Bmin = 200 mm
Amax = 1400 mm (extra stiffeners > 1000 mm)
Bmax = 4000 mm


Date	12.11.2019	Rev. date	04.10.2023	Work nr.	Drw. nr.	Rev.
Drawn by	Ruukki	Rev.	P03		S150DM02	e
Scale	1:2.5	Building			File nr.	

Joint details applicable to all panel types


Horizontal joint (hidden fix)



Horizontal joint (replacable)



Vertical joint



panel depth C = 40 mm
horizontal joint Dh = 5-35 mm
vertical joint Dv = 5-25 mm
material thickness t = 4.0 mm (ACM)
weep holes at the bottom 15x5 mm, max c/c 300mm



Contents of drawing




Primo Skyline 150

Corner panel

Dimensional drawing

Date	25.10.2019	Rev. date	04.10.2023	Work nr.	Drw. nr.	Rev.
Drawn by	Ruukki	Rev.	P03		S150DM03	d
Scale	1:10	Building			File nr.	

Bracket cutouts/side	
Height	Cutouts
< 950	1
950-1699	2
1700-2449	3
2450-3199	4
3200-3950	5
> 3950	6



panel depth C = 40 mm
horizontal joint Dh = 5-35 mm
vertical joint Dv = 5-30 mm
material thickness t = 4.0 mm (ACM)
weep holes at the bottom 15x5 mm, max c/c 300mm

Amin, Bmin = 200 mm
(A1+A2) max = 1400 mm
Amax = 800 mm
Bmax = 4000 mm

Vertical joint 1:5

