

## **Appendix to assembly instruction - sandwich panels**

1. Wall panel orientation, Horizontal or Vertical (H/V), relates to the long joint orientation.
2. LPCB Ref 1052a/02 EXT-B grade ceiling panels, joint shall be stitched on the external face using 4.9x19mm zinc coated carbon steel self drilling fasteners at nominal 300mm centres.
3. LPCB Ref 1052a/02 EXT-A15 80/40, 100/60, 120/80, 140/100 and 210/170 ceiling panels were fire resistance tested with an imposed load of 24kg/m<sup>2</sup>. The maximum unsupported span shall be limited to 2.0m between supports and the panel joints shall be stitched on the external face using 4.9x19mm zinc coated carbon steel self drilling fasteners at nominal 300mm centres.
4. LPCB Ref 1052a/02 EXT-A30 grade 120/80, 140/100 and 210/170 ceiling panels were fire resistance tested with an imposed load of 32kg/m<sup>2</sup>. The maximum unsupported span shall be limited to 2.0m between supports and the panel joints shall be stitched on the external face using 4.9x19mm zinc coated carbon steel self drilling fasteners at nominal 300mm centres.