

# PRODUCT CERTIFICATE

## **Ruukki Construction Oy**

manufactures

### **Sandwich panels**

Products are prefabricated metal faced sandwich panels which are aimed to be used as burglar protection walls. This certificate is based on an initial type assessment of the product and an initial inspection of the factory production control according to the certification criteria R066. The characteristics of the sandwich panels have been tested at Eurofins Expert Services Oy. The assessment is based on the test results and evaluation.

The certificate concerns following products:

**SPA 150 E –SPA 230 E, SPA 150 E LIFE – SPA 230 E LIFE, SPA230 E LIFE  
FORMA, SPA 150 S – SPA 230 S, SPA 150 F – SPA 230 F, SPA 200+ EE - SPA  
300 EE, SPA 150 E LIFE PATINA - SPA 230 E LIFE PATINA, SPA 150 E PATINA -  
SPA 230 E PATINA, SPA 150 F PATINA - SPA 230 F PATINA, SPA 150 S PATINA  
- SPA 230 S PATINA, SPA 200+ EE PATINA**

A summary of the characteristics is presented in Table 1.

According to the results products can be used as burglar protection walls.

This certificate is valid until October 30, 2030 on condition that the product is not essentially changed and the manufacturer and Eurofins Expert Services Oy have a valid contract on quality control. To check the validity of this certificate, [www.sertifikaattihaku.fi](http://www.sertifikaattihaku.fi). Other conditions are listed on page 4.

Espoo, October 30, 2025

Katja Vahtikari  
Manager, Product Certification

Samuli Korkiakoski  
Senior Expert

*This document has been signed electronically*

# PRODUCT CERTIFICATE

Table 1.

Product	Testing Method	Requirement	Protection class
SPA150 E (0.6/0.5), SPA 200 E(0.6/0.5) and SPA 230 E (0.6/0.5)	SSF 1047	3 min	1
SPA 200+ EE (0.6/0.7)	SSF 1047	3 min	1
SPA150 E LIFE (0.6/0.5), SPA 200 E LIFE (0.6/0.5) ja SPA 230 E LIFE (0.6/0.5)	SSF 1047	5 min	2
SPA 200+ EE (0.6/0.5) with profiled sheeting reinforcement <sup>1</sup>	SSF 1047	5 min	2
SPA230 E LIFE FORMA	SSF 1047	5 min	2
SPA 150S, SPA 175 S, SPA 200 S and SPA 230 S	SSF 1047	5 min	2
SPA 150 F, SPA 175 F, SPA 200 F and SPA 230 F	SSF 1047	5 min	2
SPA 150 F, SPA 175 F, SPA 200 F and SPA 230 F with plywood reinforcement <sup>2</sup>	SSF 1047	10 min	3
SPA 150 F, SPA 175 F, SPA200F and SPA230F with profiled sheeting reinforcement <sup>3</sup>	SSF 1047	10 min	3
SPA 200+ EE (0.6/0.5) and SPA 300 EE (0.6/0.5) with profiled sheeting <sup>4</sup>	SSF 1047	5 min	2
SPA 200+ EE (0.6/0.5) and SPA 300 EE (0.6/0.5) with profiled or flat sheeting <sup>5</sup>	SSF 1047	10 min	3
SPA 150 E (0.6/0.5), SPA 175 E (0.6/0.5), SPA 200 E (0.6/0.5) and SPA 230 E (0.6/0.5) with profiled sheeting <sup>4</sup>	SSF 1047	5 min	2
SPA 150 E (0.6/0.5), SPA 175 E (0.6/0.5), SPA 200 E (0.6/0.5) and SPA 230 E (0.6/0.5) with profiled or flat sheeting <sup>5</sup>	SSF 1047	10 min	3
SPA 150 E LIFE PATINA (0.7/0.5), SPA 200 E LIFE PATINA (0.7/0.5) and SPA 230 E LIFE PATINA (0.7/0.5)	SSF 1047	5 min	2
SPA 150 E PATINA (0.7/0.5), SPA 200 E PATINA (0.7/0.5) and SPA 230 E PATINA (0.7/0.5)	SSF 1047	3 min	1
SPA 150 F PATINA (0.7/0.5), SPA 200 F PATINA (0.7/0.5) and SPA 230 F PATINA (0.7/0.5)	SSF 1047	5 min	2
SPA 150 S PATINA (0.7/0.5), SPA 200 S PATINA (0.7/0.5) and SPA 230 S PATINA (0.7/0.5)	SSF 1047	5 min	2
SPA200+ EE PATINA (0.7/0.5)	SSF 1047	3 min	1

---

# PRODUCT CERTIFICATE

---

1, 2, 3, 4, 5 Further clarifications are given below:

- <sup>1</sup> Profiled sheeting (minimum height 18 mm, material thickness 0,6 mm) reinforcement on the back side
- <sup>2</sup> Plywood (thickness 12 mm, type Wisa Form Birch with 9 plies) reinforcement on the back side
- <sup>3</sup> Profiled sheeting (height 20 mm, material thickness 0,6 mm) reinforcement on the back side
- <sup>4</sup> Ruukki profiled sheeting (0.6 mm thickness) or Ruukki Primo Skyline (material thickness 0,6 mm) on external facing if the CA1SS1 support stud spacing is > 400 mm
- <sup>5</sup> Ruukki profiled sheeting (0.6 mm thickness) or Ruukki Primo Skyline (material thickness 0.6 mm) on external facing if the CA1SS1 support stud spacing is ≤ 400 mm.

---

# PRODUCT CERTIFICATE

---

No EUFI29-20005093-C  
Update October 30, 2025

4 (4)

The validity of the certificate will be ended, if the product falls into the scope of CE-marking.

Where reference is made in this certificate to any regulations, publications, standards or other documents, it shall be construed as a reference to such publication in the form of which it is in force at the date of this certificate.

The manufacturer is responsible for the quality and continuous quality control of the product. In granting this certificate, Eurofins Expert Services Oy does not accept responsibility to any person or body for any loss or damage incurred in respect of personal injury arising as direct or indirect result of the use of this product.

The use of the name of Eurofins Expert Services Oy or the name Eurofins in any other form in advertising or distribution in part of this certificate is only permissible with written authorisation from Eurofins Expert Services Oy.